



Notified body No. 1121

Certificate of Constancy of Performance 1121-CPR-AD5378

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

(INDOOR / FAULTLESS / FORTRESS / ARCTEK / LOCWARE / LEADO / DURASET) T96M Concealed Door Closer

Intended use: For use on fire / smoke compartmentation single leaf and double leaf doors CONCEALED IN DOOR APPLICATION.

Essential characteristics	Performance	Harmonised technical specification
	Mechanical Test Evidence: WIL 375896 Fire Test Evidence: 375219 Iss 2 & 385688.	
Self closing		
5.2.1 General		
5.2.2 Durability	500,000 test cycles	
5.2.3 Closing moment	Pass size 3 to 6	
5.2.4 Opening moment	Pass size 3 to 6	
5.2.5 Efficiency	>55% size 3	EN 1154:1996/A1:2002/AC:2006
5.2.5 Efficiency	>65% size 6	
5.2.6 Closing time	Pass	
5.2.7 Angles of operation	Grade 3, > 105°	
5.2.8 Overload performance	Pass	
5.2.9 Temperature dependence	-15°C to +40°C	
5.2.10 Fluid leakage	Pass	
5.2.11 Damage	Pass	
5.2.12 Latch control	Pass	
5.2.13 Back check (optional)	NPD	
5.2.14 Delayed closing (optional)	NPD	
5.2.15 Adjustable closing force (optional)	Pass	
5.2.16 Zero position (double action door closers only)	NPD	
5.2.18 Fire/smoke door suitability	Pass	1
Essential characteristics	Performance	Harmonised technical specification
Durability of Self Closing	500,000	
5.2.2 Durability 5.2.17.1 corrosion	500,000 test cycles	4
	Grade 3 (96 hours)	1
5.2.17.2 corrosion	Pass	EN 1154:1996/A1:2002/AC:2006
Dangerous Substances Annex ZA3	Pass: the materials in the door closer do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	

Page 1 of 2





Certificate of constancy of performance 1121-CPR-AD5378

produced for

Fortress Industrial Co.,Ltd No.103, Xingong 1st Rd., Beidou Township, Changhua County 521, Taiwan. R.O.C

and produced in the manufacturing plant

K/002

This is coded format and the information is held by the Notified Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 1154:1996/A1:2002/AC:2006

under system 1 of AVCP are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 12/02/18 and revised on 27/02/18 will remain valid to the date given below as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Valid to: 11/02/21

Paul Duggan Certification Manager

Exova (UK) Limited trading as Warrington Certification Holmesfield Road, Warrington, Cheshire, WA1 2DS, UK



Page 2 of 2